IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Statesville Auto Auction DATE 4-1-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N - 1-77 at Five Mile Branch

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. 21 N

House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil Cecil

Percolation Rate 1" – 45 min

Topography Level

Depth to Water Table 25+

Rock or other impervious formations None



Plot of System

Size of Tank 2250 Gals.

Nitrification Field:

No. of Lines 8

Sq. Ft. 2220 Linear Ft. 740

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Harlan Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Todd Jr. DATE 4/2/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold