IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp. DATE 10-11-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Rt 2171

S. R. No. _____


SUBDIVISION NAME Danbury Forest LOT NO. 60 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (/)	Character & Porosity of Soil	CSB2
Auto. Dishwasher	Yes (/)	No ( )	Percolation Rate	mod
Auto. Wash. Machine	Yes (/)	No ( )	Topography	2 to 6%
Site Suitable	Yes (/)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 1/2 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (/)

Installed by Pssst Sale

IMPROVEMENTS PERMIT BY P. C. Moore relay out

COMMENTS: Soil Conditions 36" town were better than originally thought

CERTIFICATE OF COMPLETION BY P. C. Moore DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold