IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 6-1-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 N TR on 2171

S. R. No. _____


SUBDIVISION NAME Danbury Forest LOT NO. 65 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Fine Sandy Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 min / inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Pfass & Sale
+ French Drain around System – 56 Tons of stone – to intercept ground water average depth 9' to 6'

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape so water will not stand over Tank or lines. French Drain installed by Fortis Corp.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 6-1-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold