IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 5-18-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 055 Jane Sowers Rd

S. R. No. _____

SUBDIVISION NAME Danbury Forest LOT NO. 45 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Cecil Fine Sand & Clay
Percolation Rate 80 min/inch
Topography 4 to 10%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Pfaff & Sale

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: landscape so water does not stand over tank or lines.

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-18-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold