IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Church of the Latter Day Saints DATE 17 Oct 73 PERMIT NO. _____

PHONE: Business ~~[illegible]~~ Home _____

LOCATION 21N to Rd # 2171 on Right. 1/2 to Rd # 2174 on Right. Church on corner on Right S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	17
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	level
Size Suitable	Yes (✓)	No ( )	Depth to Water Table	unk
			Rock or other impervious formations	none

Total Area _____



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 8
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Robert Hall + Jane Fay

IMPROVEMENTS PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 18 Oct 73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold