IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp. DATE 5-4-79 PERMIT NO.

PHONE: Business Home

LOCATION Jane Sowers Rd

S. R. No.

SUBDIVISION NAME Danbury Forest LOT NO. 39 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil clay
Percolation Rate 30
Topography 2 to 6%
Depth to Water Table 10' +
Rock or other impervious formations none

Lot Area 1/2 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10
Water Supply: Individual ( )
Public (✓)

Installed by Passat Sale

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: landscape so water will not stand over lines or tank

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold