IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R.C. Redmond DATE 18 Mar 77 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 21N to Statesville auto sales on Rt 4. (2172) Approx. 7 mile Driveway on left. Trailer back off road beside house. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	1½	Character & Porosity of Soil	Red Clay
Garbage Disposal Unit	Yes ( )		No (✓)	Percolation Rate	none
Auto. Dishwasher	Yes ( )		No (✓)	Topography	Flat to slope
Auto. Wash. Machine	Yes (✓)		No ( )	Depth to Water Table	well
Site Suitable	Yes (✓)		No ( )	Rock or other impervious formations	well

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

well at house not shown

Installed by Jesse Hartman

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY C.R. Redmond DATE 18 Mar 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold