IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR McKinney Realty DATE 6-22-78 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 21 N TR on Rd #2174 - to Wildwood Estates Imperial Dr.

SUBDIVISION NAME Wildwood Estates LOT NO. 204 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	LFBz
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4ft
Lot Area _____			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Carter Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 6/22/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold