HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D # 10B-A-55(1)
PROPERTY RECORDED
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C.D. MADISON OWNER: AGENT: PHONE: 873-0521
ADDRESS: 1805 SAPPHIRE RD APPLICATION DATE: 5-15-96 DATE EVALUATED: 6-15-96
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE W/CS
PROPERTY SIZE: 20,957.95 FT2
LOCATION OF SITE: ROLLING MEADOWS #3
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	4% L	0-6	SCL	GR	1:1 /FR	1941 WETNESS CONDITION	S
		6-48	C	WMSBK	1:1 /FI/SS	.1943/.1956 SAPROLITE	S
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25 GPD/FT2
2	4% L	0-3	SCL	GR	1:1 /MFR	1941 WETNESS CONDITION	S
		3-28	C	WMSBK	1:1 /FI/SS	.1943/.1956 SAPROLITE	S
		28-48	C	WMSBK MOTTLES/MAN	1:1 /FI/S/SP	1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25 GPD/FT2
3						.1941 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						1941 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1941 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						1944 RESTRICTIVE HORIZON	-
						1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE 0.25 GPD/FT
OTHER FACTORS(.1946) NONE SYSTEM TYPE CHAMBERED GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT DOUG MADISON, MIKE GAITHER, BOBBY GIBSON
COMMENTS

DRAFT

001717