HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D # 10-B-A-55
PROPERTY RECORDED
COUNTY: REDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C.D. MADISON OWNER: AGENT ✓ PHONE: 873-0521
ADDRESS: 1805 SAFRIET RD APPLICATION DATE: 5-15-96 DATE EVALUATED: 6-15-96
STK, NC 28677 PROPOSED FACILITY: 3BR HOUSE W/ C.S.
PROPERTY SIZE: 21,657.95 FT²
LOCATION OF SITE: #2 ROLLING MEADOWS
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 4%	0-7	SC	WMSBK	1:1 /FR	1942 WETNESS CONDITION	S
		7-23	C	WFSBK	1:1 /FI/SS/SP	1943/.1956 SAPROLITE	S
		23-48	C	WFSBK	1:1/F/NS/NP	1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25
2	L 4%	0-10	SC	WMSBK	1:1/ FR	1942 WETNESS CONDITION	S
		10-46	C	MSSBK	1:1/FI/SS/SP	1943/.1956 SAPROLITE	D
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1945): PS SITE LONG-TERM ACCEPTANCE RATE 0.25 GAD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CHAMBERED GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT DOUG MADISON, MIKE CARTER, RODDY GIBSON
COMMENTS

DRAFT

00135