IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Wesley Davis Jr. DATE 8-30-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 66 E. Left on Old Mocksville Rd. #2158 - Go 1½ mile Tr on Rd # 2192 - 4th Mobile Home on left S. R. No. 2192


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Fair
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope To Rear
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	n/a
			Rock or other impervious formations	None

Lot Area 1 Acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 350
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Mason & Grant

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn T. Ledford DATE 8/30/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold