IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hoover's Bldg Co. DATE 2/14/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N., Rt on 2171, Left on 2172, 1st House on Left

SUBDIVISION NAME Wildwood 106-5 LOT NO. (213) SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

75

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 100 X 200 Approx


Character & Porosity of Soil Red Clay

Percolation Rate ~

Topography slope to front

Depth to Water Table ~

Rock or other impervious formations none known



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Garbage disposal may be installed in home

CERTIFICATE OF COMPLETION BY Andrew E. Carney DATE 2-14-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold