IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roby Houston DATE 30 June 95 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 N to Rt 2171 to Wildwood Acres - on left beyond Rt 2197. S. R. No. _____

SUBDIVISION NAME Wildwood Acres LOT NO. 185 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Red Clay - Tight
Percolation Rate 60 min
Topography Level
Depth to Water Table ok
Rock or other impervious formations ok



Plot of System Rt 2171

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W W Howard DATE 30 June 95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold