IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lenhaus Bldg Co. DATE 6-26-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. LEFT ON OLD MOCKSVILLE RD 1st 2155 LEFT ON RD 2192 60 3/4 MILE - NEW HOUSE ON LEFT S. R. No 2192

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1.6 ACRES

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slope to back
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 637 Linear Ft. 255
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lenhaus Bldg. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glynn Todd DATE 6/26/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold