IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hanlon Bldg. Co. DATE 9-14-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N. Hwy 21 #3171 - to Meadowview Estates

S. R. No. _____


SUBDIVISION NAME Meadowview Estates LOT NO. 36 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to back
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	none

Lot Area 24192



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 252
Depth of Stone in Lines 10

Water Supply: Individual ( )
Public (✓)
Iredell Water Corp.

Installed by Hanlon Bldg Co Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Ford DATE 9/19/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold