IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Brewer DATE 9 July 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 N. T R on Rt # 2171 at Statesville Hobbley.

S. R. No. _____

SUBDIVISION NAME Meadowview LOT NO. 32 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area _____


Character & Porosity of Soil CHC2

Percolation Rate one

Topography Slope to rear

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Iredell Water Corp

Installed by Hall Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY WM Edwards DATE 9 July 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold