HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jacob Dyson OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: .552 acres
LOCATION OF SITE: Clemmons, NC
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 6%	0 to 4	L	GR		.1942 WETNES CONDITION	N/A
		4 to 28	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		28 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	linear 6%	0 to 4	L	GR		.1942 WETNES CONDITION	N/A
		4 to 30	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	linear 5%	0 to 2	L	GR		.1942 WETNESS CONDITION	N/A
		2 to 30	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 48	CL	SBK weak	1:1	.1944 RESTRICTIVE HORIZON	PS
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE conv. Gravity
EVALUATED BY: R. C. Moore OTHER(S) PRESENT: Jacob Dyson
COMMENTS: _____

DRAFT