IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Dellinger DATE 11/16/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION U.S. 21 N., T.R. on 2171, 2 mile T.R. into woodsview

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 2+3 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre


Character & Porosity of Soil Clay + parent material

Percolation Rate 60 min/inch

Topography 4-6% slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Eidelei County

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 11/16/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold