37048

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

11464

OWNER OR CONTRACTOR J & D BLDG CO. DATE 7/20/90 PERMIT NO. 106-6-A-51

PHONE: Business _____ Home _____

LOCATION DELLINGER DR S. R. No. _____

SUBDIVISION NAME MEADOWVIEW LOT NO. 51 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )


Character & Porosity of Soil CLAYEY
Percolation Rate .4
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations NONE

Lot Area 18,000 SQ FT+ P.L. 10'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 GAL. 1000 P.T. Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by DENNIS GAULLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Hayes / J.C. Moore DATE 7/20/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold