Randleman Const. Co.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Randleman DATE 4/11/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N., T.R. on 2171 to Meadowview

S. R. No. _____

SUBDIVISION NAME Meadowview Estates #2 LOT NO. 50 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil CfB2


Percolation Rate mod

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Lot Area 100 X 180



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Clayton Blevins

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Covey DATE 4/11/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold