36606

11221

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C) 106-6-A-49

OWNER OR CONTRACTOR DENNIS DEAL DATE July 6, 1990 PERMIT NO. 106-6-A-49

PHONE: Business _____ Home _____

LOCATION DELLINGER DR. OFF JANE SOWERS RD - HOUSE ON RT ACROSS FROM OWL HOLLOW DR. S. R. No. _____

SUBDIVISION NAME MEADOWVIEW LOT NO. 49 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil CLAYEY
Percolation Rate 3
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations NONE

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 GT. / 1000 PT Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 1170 Linear Ft. 390
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by DENNIS GAUTHER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: 390 LINEAR FEET OK BY K.S. & R.S.H.

CERTIFICATE OF COMPLETION BY _____ DATE 7/6/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold