IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ievan Builders DATE 9-6-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 N TR on 2171 1½ mi on R

S. R. No. _____


SUBDIVISION NAME Meadow View LOT NO. 5 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Sandy loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	45 min / inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 3% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	none	

Lot Area 15,000 Sq'



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 795 Linear Ft. 265
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: landscape + pipe Gutters so that water will not stant over Tank or lines

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 9-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold