37647

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alan Lewis DATE 10-25-90 PERMIT NO 106-6-A-10

PHONE: Business 878-2305 Home

LOCATION 21 N TR Jane Sowers Past Donna Lane 3rd Lot on Rt

S. R. No.

SUBDIVISION NAME Meadowview II LOT NO. 10 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clayey
Percolation Rate 14
Topography 2+49's
Depth to Water Table 24
Rock or other impervious formations none


Lot Area 20,220 Sq'

____ Basement with Plumbing ____ Basement without Plumbing (✓) No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by Tommy Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 10-25-90

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold