IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pat O'Conner DATE 6-28-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Brookview MHP lot 18-A

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	.4 gal/sq ft/day
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2 to 6%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area _____

_____ Basement with Plumbing _____ ~~Basement~~ without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by AAA Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 6-28-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold