IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Boan Bldg Co. DATE 8-14-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on Rt 2171


S. R. No. _____

SUBDIVISION NAME Meadowview LOT NO. 16 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sc c
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2+0 6-20 slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1/2 acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. C. Moody DATE 8-14-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold