IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Levan Bldg. Co. DATE Feb. 17, 1978 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N T.R. on 2171

S. R. No. _____


SUBDIVISION NAME Meadowview Estates LOT NO. 4 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	C f Bz
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	mod
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.
			Rock or other impervious formations	none obs.

Lot Area _____



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16" +

Water Supply: Individual ( )
Public (✓)

Installed by Roy Lentz

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles R. Johnson DATE Feb-17-'78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold