IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edwin Hunter Homes DATE 8-2-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on 2171 TR into _____ S. R. No. _____


SUBDIVISION NAME Meadow View LOT NO. 15 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 4 acres

Character & Porosity of Soil Cecil clay loam
Percolation Rate mod to slow
Topography 4% to slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY ~~J. C. Moore~~ ~~Glenn Fox~~ DAVID HINSON 2/17/78

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-2-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold