IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

8346

OWNER OR CONTRACTOR Hunter Bajack DATE 11/2/88 PERMIT NO.

PHONE: Business Home

LOCATION Dellinger Dr S. R. No.

SUBDIVISION NAME Meadowview LOT NO. 42 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area 100 X 165

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
96' Sq. Ft. Linear Ft.
Depth of Stone in Lines
Water Supply: Individual ( )
Public ( )

50' 16" T+J Panel

Installed by Eddie Yount

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed

2/21/2013 LOT 100' BACK OF LOT 96' FROM HOUSE

IMPROVEMENTS PERMIT BY JC Means

COMMENTS: pump to the back for Repair

CERTIFICATE OF COMPLETION BY JC Means DATE 11/2/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy

Location of the proposed Storage Building addition does not appear to impact the existing on-site septic system.**NOTE: JR Hinson REHS

Date: 2-21-13

ICHD-Environmental Health Division

er's Copy: Gold