HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Alan Lewis OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10-21-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	linear 6%	0 to 4"	L	GR		1942 WETNESS CONDITION - N/A
		4 to 36	C	SBK	1:1	1943 1956 SAPROLITE - N/A
		36 to 42	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
		42 to 48		Transition		1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - 1.35
2	linear 6%	0 to 4"	L	GR		1942 WETNESS CONDITION - N/A
		4 to 42	C	SBK	1:1	1943 1956 SAPROLITE - N/A
		42 to 48	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - 1.35
3	linear 6%	0 to 4	L	GR		1942 WETNESS CONDITION - N/A
		4 to 36	C	SBK	1:1	1943 1956 SAPROLITE - N/A
		36 to 42	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
		42 to 48	C	f sap	Transition	1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - 1.35
4						1942 WETNESS CONDITION -
						1943 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 1.35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: R.C. moore OTHER(S) PRESENT:
COMMENTS:

DRAFT