IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edgar Cranfield DATE Aug. 15, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N Rt. on SR 2171 2.2 mi. on Rt.

S. R. No. _____


SUBDIVISION NAME Meadowview LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft	
			Rock or other impervious formations	none observed	

Lot Area 2 1/2 acres



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hoke Bros.

IMPROVEMENTS PERMIT BY Andrew E Carney

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R Hinson DATE Aug 15, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold