## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Horne DATE 7-20-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on Rd #2171 to Meadowview Estates (Dellinger Rd.) S. R. No. _____


SUBDIVISION NAME Meadowview Estates #2 LOT NO. 59 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 100 x 200

Character & Porosity of Soil Red Clay
Percolation Rate 60
Topography Slope to Back
Depth to Water Table 25
Rock or other impervious formations Stone



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 350
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Drainfield shallow - yard should be graded and sloped to direct surface water away from drainfield

CERTIFICATE OF COMPLETION BY Lloyd Fox Jr. DATE 7/26/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold