Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4756-57-6-3013
Lot #: MEADOW VIEW 59
Permit #: 225402
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: KEVIN OSBORNE
Address: 1616 BECKINGER DR.
Proposed Facility: SFR
Location of Site: SAME
Design Flow (.1949): 360
Applicant: SAME
Date Evaluated: ~~10/4/2016~~ 3-15-17
Property Size: .46 AC
Property Recorded: YES
Water Supply: [M] Public [ ] Individual [ ] Well [ ] Spring [ ] Other
Evaluation Method: [M] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [M] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941 .1941 Structure/ Texture	1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB 1	L 6%	0-28	SCLWSBK	SS	CCH2 @ 42"	48"	(U)	42"	1225
		28-42	SCWSBK	SS					
		42-48	CSAP	STICKY					
AB 2	L 6%	0-20	SCLWSBK	SS	COMMY/BR @ 44"	48"	—	48"+	125
		20-48	RC[illegible]SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)		DS
System Type(s)		25%
Site LTAR		1225

Other Factors (.1946): —
Soil Evaluation By: BEN ALDRIDGE
Others Present: STEVE JORDAN, KEVIN OSBORNE
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: STEVE JORDAN, KEVIN OSBORNE