IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR United Builders DATE Aug 26, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION U.S. 21 N T.R. on SR. 2171 to Meadowview

SUBDIVISION NAME Meadowview Estates " LOT NO. 63 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area _____


Character & Porosity of Soil CFBz

Percolation Rate —

Topography 2-4%

Depth to Water Table sink.

Rock or other impervious formations none to.



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Eddie Yountz, Sons

IMPROVEMENTS PERMIT BY Glenn Foy

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE Aug 26, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold