8231

Clay Gentry

IREDELL COUNTY HEALTH DEPARTMENT Permit # 200787

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dan Holmes DATE 11-30-88 PERMIT NO B-11

PHONE: Business _____ Home _____

LOCATION Baymount Dr. S. R. No. _____

SUBDIVISION NAME Baymount LOT NO. 24 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 1 acre+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gal's.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Younts & Sons

I understand and agree to install septic tank system as specified on this Improvements

Location of the proposed 22' x 29' Garage addition does not appear to impact the existing on-site septic system.**NOTE:

Justin Henderson REHS
Date: 1-2-14
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: 22' x 29' Garage

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 11-30-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold