8771

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 4-11-89 PERMIT NO. B-11

OWNER OR CONTRACTOR Jerry morris Home

PHONE: Business

LOCATION Baymount Lot 12 NCW section S. R. No.

LOT NO. SECTION OR BLOCK NO.

SUBDIVISION NAME

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable

Lot Area 1.257 acres

Character & Porosity of Soil Clayey

Percolation Rate 35

Topography 2 to 6%

Depth to Water Table 10+

Rock or other impervious formations none

___ Basement with Plumbing ✓ Basement without Plumbing ___ No Basement

Size of Tank 1500 Gals.


Nitrification Field:

No. of Lines 5

Sq. Ft. 1340 Linear Ft. 448

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by James Hutler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY D. C. moore

COMMENTS: Route water line around septic Tank System.

DATE 4-11-89

CERTIFICATE OF COMPLETION BY D. C. moore DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold