8943

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Strauss DATE 10-20-88 PERMIT NO. B-11

PHONE: Business _____ Home _____

LOCATION Baymount Meadows lot 7 New Section S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1.249 acres

Character & Porosity of Soil Clayey
Percolation Rate 14
Topography 2 to 6 %
Depth to Water Table 10'+
Rock or other impervious formations Saprolite mottling 36" to 48"

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1000 gal Pump Tank
Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: Pump + Alarm to be wired to Iredell Co. building Insp. Dept. rules + Standards. 1/2 hp Liberty Pumps set - EE 51 model No.

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 10-20-88

EXISTING SYSTEM CHECKED BY. _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold