Award Pools

201584 [redacted]

TYPE III (OTHER THAN III D)

L COUNTY HEALTH DEPARTMENT
STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281
'EMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PIN# 4756595119
PLICANT Christine Swaney PHONE: Business _____ Home 704-876-4860 DATE 8-7-07
29 Belmont Drive Statesville NC 28625
N Bellaire Sewer RD Baumont plat Lot 8
Day-mart BLOCK / SECTION _____ LOT _____ LOT AREA 1.91 SITE CLASS PS DESIGN FLOW 480 L.T.A.R. 3
Gallons: ST 8 _____ Date _____
Gallons; PT _____ Date _____
Model _____ Serial No. _____
: No Fields _____ Square Feet 1600 Linear Feet 260
Trench Width 24" Max Trench Bottom Depth 36"
☐ New System ☑ Repair ☐ Expansion System Type: I II III IV V VI
System Description: _____
Repair System Description: 50% Lateral Rest
Maintenance Agreement Required: ☐ Yes ☑ No
Gravel Depth NA ☐ Gravity ☑ Pressure
☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons 2 No. Employees _____
Water Supply: ☐ Individual ☐ Public ☐ Community
☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing
ions: Repair 4 New lines (a) 67' 50% reduction panel system - 34' a pump tank to have to be installed.

INITIAL SITE SKETCH

Comments/Conditions:
United system designed in 1988 Repair evaluated and designated in 2007

AS BUILT SKETCH

ed or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

[signature] Dyson Agent date 8-7-07 Installed by: James Hudler Installed 2-588
: _____ date _____ Operation Permit by: [signature] date 8-7-07
uct by: _____ date _____ Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (IMPRAL): PINK

Location of the proposed Pool addition does not appear to impact the existing on-site septic system or well.NOTE:** [signature] **REHS Date:** 02/10/14
ICHD-Environmental Health Division