32822

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

9314

OWNER OR CONTRACTOR John Sadowski DATE 9789 PERMIT NO. 811

PHONE: Business _____ Home _____

LOCATION Bayground Meadows II

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 16 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 2.1 AC

Character & Porosity of Soil Clayey
Percolation Rate 25 min/in
Topography Slight
Depth to Water Table 10 ft
Rock or other impervious formations None

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DE Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY DMoore DATE 9789

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold