IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Allen Mearemore DATE 5-17-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E. Left on (Old Mocksville Rd) #2158 - left on Rd # 2192 - Brookview T.P. S. R. No. _____

SUBDIVISION NAME Brookview Trade Park LOT NO. 25-A SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 100X200


Character & Porosity of Soil Red Clay

Percolation Rate ~

Topography Slope To Rt.

Depth to Water Table ~

Rock or other impervious formations ~



Plot of System

Size of Tank 1,000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hurlie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew Canupp DATE 5-15-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold