IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hunter Homes DATE 8/4/78 PERMIT NO.

PHONE: Business Home

LOCATION 2 N., T.R. on Rd #2171 - Meadowview II

S. R. No.


SUBDIVISION NAME Meadowview Estates II LOT NO. 14 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	LCC3	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	mod	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk	
			Rock or other impervious formations	some rock	

Lot Area Lacr



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew E. Caudle DATE 8/4/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold