# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR ~~CONTRACTOR~~ Rel S.D. BAKER DATE 11-16-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N- Rt on Rd. 2171. to MEADOWVIEW ESTATES – on Rt before Baymont MEADOWS. S. R. No. 2171

SUBDIVISION NAME Meadowview Estates LOT NO. 24 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) | |
| Auto. Dishwasher | Yes (✓) | No ( ) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Character & Porosity of Soil Red clay
Percolation Rate med
Topography Level
Depth to Water Table ample
Rock or other impervious formations none

Lot Area 2 acres




Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 667 Linear Ft. 253
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Raymond Adkins
Hiddenite, NC.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Lofquist DATE 11-16-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold