13322

IREDELL COUNTY HEALTH DEPARTMENT

41017

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Fox DATE 12-13-91 PERMIT NO. 106-6-A-71

PHONE: Business _____ Home _____

LOCATION Hwy 21N TR J. Sawyer Rd TR Dellinger Dr. 400' on left. S. R. No. _____

SUBDIVISION NAME Meadow View Est. LOT NO. 71 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clayey
Percolation Rate .26
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 20,000 sq'+

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-1 Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY F. C. Moore DATE 12-13-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold