IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Statesville Racquet + Swim Club- DATE 8-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Raymount Meadows- off Rd # 2171

S. R. No. _____


SUBDIVISION NAME Raymount Meadows- LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Racquet + Swim Club- Membership- 352

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	1" – 60 min
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	Slope to Back
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+
			Rock or other impervious formations	None

Lot Area Adequate



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. 2106 Linear Ft. 702
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Sam Retherford

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic Tank System Designed for Bath Houses only – Water line to be 10' from any part of Septic Tank System

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 8/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold