IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T.L. Dysard + Son Inc DATE 5-31-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. Left on Rd #2158 old Mooresville Rd - Go 1 3/4 mile - on left.

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms 1 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area 5 Acres

Character & Porosity of Soil Red Clay
Percolation Rate same
Topography Slope to Front + Left side
Depth to Water Table over
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 5/31/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold