IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy F. Sutton DATE 11-23-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. TL on RT 2157 (Old Mocksville Rd) TR on Rd 2183 - House on Rt. S. R. No. 2183


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight slope to left.
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25
			Rock or other impervious formations	none

Lot Area 1 Acre



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by Ellis Grading & Sons

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 11/29/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold