39931

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12780 OWNER OR CONTRACTOR JOHN W McCOY DATE 6/27/91 PERMIT NO. 11E-A-69

PHONE: Business _____ Home _____

LOCATION 64 E, TL OLD MOCKSVILLE RD, PAST BROOKVIEW ROAD, BEHIND 2ND HOUSE ON (L) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other ADDITION OF ROOM & PLUMBING

No. Bedrooms 1 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1 AC.

Character & Porosity of Soil PS

Percolation Rate .4 GPD/FT2


Topography 2-6%

Depth to Water Table >4'

Rock or other impervious formations NONE

TP 3/4/91

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 210

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by TOMMY FRYE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. MOORE

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 6/27/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold