DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Kent Nicholson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8-17-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	8% linear	0 to 8"	L	GR		.1942 WETNESS CONDITION - N/A
		8" to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	6% linear	0 to 9"	L	GR		.1942 WETNESS CONDITION - N/A
		9 to 32	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		32 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	6% linear	0 to 8"	L	GR		.1942 WETNESS CONDITION - N/A
		8 to 32"	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		32 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. Mooney OTHER(S) PRESENT: Kent Nicholson
COMMENTS:

DRAFT