IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Masula DATE 5-6-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N - TR on Rd #2171 - to Baymont Meadows

S. R. No. _____

SUBDIVISION NAME Baymont Meadows LOT NO. 30 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay
Percolation Rate —
Topography 2-6 % slope
Depth to Water Table sink
Rock or other impervious formations none

Lot Area _____



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 18"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Yoder DATE 5/6/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold