IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Nate Mills Jr. DATE 8-3-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on Rd # 2171

S. R. No. _____

SUBDIVISION NAME Beaumont Meadows LOT NO. 101 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 0.74 Acres


Character & Porosity of Soil LFBz

Percolation Rate Ground

Topography 2-6% Slopes

Depth to Water Table Unk

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 990 Linear Ft. 330

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Nate Mills

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn T. Dees DATE 8/3/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold