IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sherrill Lumber Co DATE 7/10/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jane Sowers Rd, T.L. on Baywood Dr. _____ S. R. No. _____


SUBDIVISION NAME Baywood LOT NO. 33 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min/inch, Approved
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 150 X 321



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hall Septic Tank Co.

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Pipe Gutters & landscape so water will not stand over lines or Tank.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 7-10-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold